

Meeting Demand, Ensuring Compliance

*A Success Story in Executing Fast-Paced Water System Improvements
in Missouri City, Texas*

APWA SE Branch – Monthly Mtg

Nicholas Cook (Missouri City, TX)

Mike Halde, PE (HR Green)

Gabby Mejia, EIT (HR Green)




Agenda

- 1 Project Overview
- 2 TCEQ ACR and Permitting
- 3 Groundwater Supply
- 4 Project Execution: Water Plant #1 & #2 Improvements
- 5 Stakeholder Coordination & Future Strategy
- 6 Key Takeaways

Project Overview


Missouri City, Texas

- ▶ Location in Fort Bend County
- ▶ Population: ~77,000 and growing
- ▶ Area: ~30 square miles
- ▶ Rapid growth → Demand on Infrastructure
- ▶ Services Area – Steep Bank/Flat Bank, Mustang Bayou, Sienna.



Missouri City Water System Overview

- ▶ Serves City, MUD 47 and MUD 48 water systems
- ▶ Emergency water supply from MUD 23 (two-way)
- ▶ Quail Valley Utility District - Operator
- ▶ Water Plant No. 1 (WP1)
 - ▶ Groundwater well (~2,100 gpm to 2,700 gpm)
 - ▶ 1 GST, 2 HPTs, and 5 booster pumps
- ▶ Water Plant No. 2 (WP2)
 - ▶ Groundwater well (~1,100 gpm)
 - ▶ 3 GSTs, 2 HPTs, and 5 booster pumps



Missouri City Project Timeline

Today's presentation includes this case-study



2024

2024 ACR: 4,755
increased to 5,333
connections

2025

Water Plant #1 Upgrade
Pumping Capacity: 29% ↑
2025 ACR: 6,333 connections

**2025
–
2027**

Water Plant #2
New 2,600 gpm well
New ground storage
tanks

2029

New 1-MG elevated
storage tank and
New surface water
transmission lines

TCEQ ACR Study and Permitting

TCEQ Alternative Capacity Requirement (ACR)

- ▶ TCEQ Chapter 290, Subchapter D, Section 45 – Capacity Rules for PWS
- ▶ What is an ACR?
 - ▶ Public Water System (PWS) specific capacity exception
 - ▶ Established different capacity for a PWS – usually lower than the Rule
 - ▶ For example, 0.4 gpm/conn of well capacity in lieu of required 0.6 gpm/conn
 - ▶ ACR rules noted are in Section 290.45 (g)
 - ▶ Who is eligible for an ACR?

TCEQ ACR for Elevated Storage Tank

- ▶ Systems with > 2,500 connections must provide 100 gallons per connection of elevated storage
- ▶ ACR allows intermediate alternative methods instead of elevated storage
- ▶ Must meet TCEQ pressure & reliability requirements
- ▶ Capacity is based on number of existing and future connections

ACR Submittal Package

- ✓ Detailed inventory of:
 - ▶ Water production
 - ▶ Storage
 - ▶ Pressure
 - ▶ Booster pumps
 - ▶ Emergency power
- ✓ 36 months of system production data
- ✓ Monthly active connection counts
- ✓ Hydraulic modeling and system evaluation signed and sealed
- ✓ Emergency Response Plan

Desktop Study – Water System Capacity Calcs

Limiting
Number of
Connections

Component	TCEQ minimum based on 30 TAC §290.45(b)(1)(D)	Existing Capacity Provided (4,832 connections)	Maximum Connections
Well Supply	0.60 gpm/conn	0.66 gpm/conn	5,333 conn
Storage Tanks	200 gal/conn	285 gal/conn	6,880 conn
Hydropneumatic Tanks	11.94 gal/conn	16.56 gal/conn	6,699 conn
Booster Pumps	0.96 gpm/conn	1.76 gpm/conn	8,848 conn
Emergency Power	Required for production/pressure maintenance during outage	950 kW total	N/A

Desktop Study – ACR Supporting Calcs for Pressure Maintenance

MDD (in gpm) =	2,509 gpm
Connections (at time of MDD) =	4,832 conn
MDD per Connection =	0.52 gpm/conn
Required Capacity per Connection =	0.60 gpm/conn
Safety Factor =	1.15
Equivalency Ratio =	0.995
Minimum Capacity Requirement =	12.0 gal/conn
Alternative Capacity Requirement (ACR) =	11.94 gal/conn
Existing Capacity Provided =	16.56 gal/conn

Fire Hydrant Flow Test

- ▶ Conducted field hydrant flow testing at 15 locations throughout the service area.
- ▶ Measured static pressure, residual pressure, and flow rates.
- ▶ Used test results to calibrate the WaterGEMS hydraulic model.
- ▶ Calibration results within 0–3.5 psi of field measurements



Fire flow testing Images

Model Scenarios


- ▶ **Average Daily Demand (ADF)** – normal daily operations
- ▶ **Maximum Daily Demand (MDD)** – highest daily demand conditions
- ▶ **Peak Hour / Power Loss** – pumps offline before generator startup
- ▶ **Emergency Operations** – system on generator power only
 - ▶ TCEQ required 0.35 gpm/conn

Hydraulic Model Results Summary


Scenario No.	Scenario Description	Condition Evaluated	Lowest Pressure (psi)
1	Existing System ADF	Normal Operations	55
2	Existing System MDD	Maximum Day Demand	47.9
3	Existing System 0.35 gpm/conn	Emergency Power	63
4	Existing System 1.5 gpm/conn	Peak Demand	57.6
5	Maximum System ADF	Normal Operations	53.1
6	Maximum System MDD	Maximum Day Demand	47.5
7	Maximum System 0.35 gpm/conn	Emergency Power	62.9
8	Maximum System 1.5 gpm/conn	Peak Demand	56.3

Results of ACR Study

- ▶ Meets TCEQ requirements
- ▶ Pressures maintained (>35 psi normal / >20 psi emergency)
- ▶ First Phase – Capacity ↑ from 4,755 to 5,333 connections
- ▶ Limiting factor: Available well production capacity
- ▶ EST project removes ACR need



Longer Term Plan



Groundwater Supply Feasibility Study

Feasibility Study Goals

- ▶ Find capacity within 12 months (min. 500 gpm)
- ▶ On-site water source
- ▶ Same water quality (i.e. disinfection treatment)
- ▶ Use existing site footprint and infrastructure

Alternative Analysis

Alternative	Project Description	Preference
1	New well at same site (same aquifer, allowing simultaneous operations)	
1A	New well at same site (same aquifer, no simultaneous operations)	
2	New well at same site (deeper aquifer)	
3	New well at different site (same aquifer)	
4	Upsize well production (pump upgrade)	

Selected Alternatives – Well Improvements

- ▶ Upsize existing well pump at Water Plant #1
 - ▶ Capacity increase: 2,100 gpm → 2,700 gpm
 - ▶ Benefits: Low cost, fast implementation, and immediate capacity increase
- ▶ New well at Water Plant #2
 - ▶ Capacity increase: 1,100 gpm → 2,100 - 2,600 gpm
 - ▶ Benefits: Same site, provides partial back up supply, and relatively faster execution

Project Execution: Water Plant #1 Improvements

WP #1 Improvement Project

- Goal: Increase groundwater production while maintaining service



Phased Implementation

Phase 1 – Temporary rental pump and disinfection system improvements:

- ▶ Validate well performance
- ▶ Successful results utilized to order pump and apply for ACR
- ▶ 36-hour test
- ▶ LAS & Chlorine treatment
- ▶ Cost: \$305,000

Phase 2 – Permanent installation:

- ▶ Wire-brush cleaning
- ▶ Long-term production increase
- ▶ Cost:\$410,000



Phase 1: Regulatory Approval

- ▶ Submitted to TCEQ:
 - ▶ Emergency Authorization Request tied to low demand period
 - ▶ Existing site photos
 - ▶ Well testing and rental pump specifications
 - ▶ Chemical feed improvement plans & calculations
 - ▶ ACR 2024 Approval
- ▶ Outcome: TCEQ approved the temporary 2,600 gpm rental pump and temporary chloramine system upgrades approved in 4 days.


Phased 1: Expansion of Chemical Feed System

Chlorine

- ▶ Chlorine system expanded from 4 cylinders to 6 cylinders
- ▶ Additional cylinder scales
- ▶ New automatic switchover system, ejector and rotameter, chlorine booster pump, chlorine gas cabinets (250 ppd to 500 ppd)

LAS

- ▶ Upsized the bulk storage
- ▶ Increase feed piping size using same injection points
- ▶ Upsized the metering pump



Phase 1: Rental Pump Design

- ▶ Same pump setting depth, increased flow – so new TDH and Flow
- ▶ Target flow: $\pm 2,600$ gpm
- ▶ Upsized the column pipe (10 in to 12 in)
- ▶ Site power used since it used the same 300 HP needed

Phase 1: Rental Pump Testing

- ▶ **Video Survey** - Assessed existing well condition.
- ▶ **Short term test (2-hr)** – Evaluated drawdown, specific capacity, sand production, motor loading, and pumping performance at increased flow rates.
- ▶ **36-hour Test** – Evaluated long-term aquifer response, drawdown, specific capacity, and sustainable well production at approximately 2,600 gpm.
- ▶ **Water Quality Report** - Collected Type A and Type B samples for water quality evaluation.

Phase 2: Permanent Pump Sizing


- ▶ Video survey confirmed the well was in good condition.
- ▶ Short-term testing verified increased pumping rates did not generate any sand.
- ▶ A 36-hour pumping test demonstrated sustainable production at 2,600 gpm.
- ▶ Intera evaluated future drought conditions, aquifer response, and total dynamic head requirements.
- ▶ Multiple pump operating points were reviewed while maintaining the existing 300 HP motor.
- ▶ A permanent 2,700 gpm pump was selected as the optimal balance between increased production and avoiding major electrical upgrades.

Phase 2: Video Surveying and Cleaning

Before Cleaning



After Cleaning



Phase 2: Pump Installation and Testing

- ▶ Pump and column pipe installation
- ▶ Disinfection of Well
- ▶ BAC-T testing
- ▶ Short-term performance testing



How Did We Accelerate Project Delivery?



ARPA Funding



**Emergency
Interconnect**



**Procurement
through interlocal
agreement**



**Accelerated
TCEQ approvals**



**Construction
duration 6-month
(Nov 25' – April 26')**

Operational Considerations During Construction

Emergency
interconnect use

Coordinate
operations between
water systems

Notify customers

Maintain system
pressure during
targeted flushing

Monitor disinfectant
residuals (chlorine vs
chloramine)

Project Results

- ▶ +600 gpm well production increase
- ▶ Increased disinfection treatment capacity
- ▶ Supported 1,000+ new connections (ACR w/ temporary rental pump)
- ▶ Maintained compliance
- ▶ Zero service interruptions



Project Execution: Water Plant #2 Improvements


WP #2 Improvement Project

- Goal: Increase production capacity



Project Details

- ▶ Construct a new groundwater well
- ▶ Increase production capacity up to 2,600 gpm (Alternative design 2100 and 2600 gpm)
- ▶ Maintain the existing well as a backup supply source
- ▶ Expand the WP#2 site onto newly acquired property
- ▶ Provide new electrical service and generator
- ▶ Two (2) new buildings – electrical and temporary disinfection system
- ▶ Temporary disinfection system – LAS & CL2-gas



Stakeholder Coordination and Future Strategy

Stakeholder Coordination

- ▶ **Regional Collaboration:** Unified service through Regional Joint Water Facilities Agreements between the City and MUDs
- ▶ **Operational Resiliency:** Trial-testing and utilizing emergency interconnects with FB MUD #23 during construction
- ▶ **Water Quality Management:** Targeted Flushing, Proactive Communication to Customers, and Enhanced monitoring during disinfection residuals conversion

Ongoing and Future Projects

Ongoing Improvements (Design Phase)

- ▶ New groundwater well at Water Plant #2
- ▶ Ground storage tanks and disinfection upgrades
- ▶ Surface Water Transmission Line

Future Projects

- ▶ Elevated storage tank Improvements

Key Takeaways

Key Takeaways

- ▶ Hydraulic modeling supports long-term planning
- ▶ TCEQ ACR - an interim solution
- ▶ Phased implementation reduces project risk
- ▶ Stakeholder partnership & coordination is critical
- ▶ EST is ultimately required



APWA - 2026 Project of the Year



Questions?



Nicholas Cook

Direct 281-403-8573
nicholas.cook@missouri
citytx.gov



Gabby Mejia, EIT

Direct 346-439-9661
gabriela.mejia@hrgreen.com



Mike Halde, PE

Direct 713-338-8015
mhalde@hrgreen.com